Your Company Name
Your Company Phone

Flue Gas Analysis

Customer
Cat A-B
WH-B1

Appliance / Location

Press: Working/Operating

Ref.

| | |
|---|---|
| Log ID | 56 |
| Date | 15:40 04 Mar 2020 |
| Fuel | Natural gas |
| O2 (%) | 5.8 |
| CO (ppm) | 83 |
| CO2 (%) | 8.7 |
| Ratio | 0.0010 |
| Pressure (mBar) | 1.03 |
| Temp net (C) | 30 |
| Temp flue (C) | 48 |
| Eff net (%) | 98.6 |
| XS air (%) | 36.4 |

Accepted by:

16:10 04-Mar-2020

KGA s/n: %3000UJE5390
Cal due 09-Nov-2020

Your Company Name
Your Company Phone

Flue Gas Analysis

Customer
Cat A-B
WH-B2

Appliance / Location

Press: Working/Operating

Ref.

| | |
|---|---|
| Log ID | 55 |
| Date | 15:47 04 Mar 2020 |
| Fuel | Natural gas |
| O2 (%) | 5.5 |
| CO (ppm) | 72 |
| CO2 (%) | 8.8 |
| Ratio | 0.0008 |
| Pressure (mBar) | 1.03 |
| Temp net (C) | 30 |
| Temp flue (C) | 48 |
| Eff net (%) | 98.6 |
| XS air (%) | 35.7 |

Accepted by:

16:10 04-Mar-2020

KGA s/n: %3000UJE5390
Cal due 09-Nov-2020

Your Company Name
Your Company Phone

Flue Gas Analysis

Customer Cat A-B
Boiler 2

Appliance / Location

Press: Working/Operating

Ref.

| | |
|---|---|
| Date | 14:09 04 Mar 2020 |
| Fuel | Natural gas |
| O2 (%) | 6.2 |
| CO (ppm) | 20 |
| CO2 (%) | 8.4 |
| Ratio | 0.0002 |
| Pressure (mBar) | 0.17 |
| Temp net (C) | 37 |
| Temp flue (C) | 49 |
| Eff net (%) | 98.2 |
| XS air (%) | 42.1 |

Accepted by:

14:09 04-Mar-2020

Your Company Name
Your Company Phone

Flue Gas Analysis

Customer
Cat A-B
Boiler 1

Appliance / Location

Press: Working/Operating

Ref.

| | |
|---|---|
| Log ID | 54 |
| Date | 14:00 04 Mar 2020 |
| Fuel | Natural gas |
| O2 (%) | 5.6 |
| CO (ppm) | 33 |
| CO2 (%) | 8.7 |
| Ratio | 0.0004 |
| Pressure (mBar) | 0.34 |
| Temp net (C) | 38 |
| Temp flue (C) | 47 |
| Eff net (%) | 98.3 |
| XS air (%) | 36.2 |

Accepted by:

14:02 04-Mar-2020